

## DECLARATION OF COMPLIANCE FOR LUMINAIRES

**Issuer:** Evolt (NZ) Pty Ltd  
**Address:** 485C Rosebank Road  
 Avondale, Auckland, 1026, NZ



## PRODUCT INFORMATION

BRAND	MODEL	SKU
Ektor	EV-MERCURY-CORE-24M-B	11802

## COMPLIANCE

2293 Report	WTF23F04091205N001
Safety Report	WTD23D04077964L
Standards	AS/NZS 60598.1 AS 60598.2.22 AS/NZS 61347.1 AS/NZS 61347.2.13 AS CISPR 15 AS/NZS 2293.3

## OPERATIONAL INFORMATION

Input voltage	230Vac
Input Frequency	50 Hz
Product Type	EM EXIT SPU

## EMERGENCY INFORMATION

Viewing Distance	24 m
Emergency Mode	Maintained
Emergency Duration	90 mins

## DECLARATION OF COMPLIANCE

On the basis of the test reports specified, I declare that the luminaire described in this document complies with the requirements of electrical safety and the use of the RCM mark.

**Title:** Managing Director **Date:** 05/01/2022

**Signature:**