

DECLARATION OF COMPLIANCE FOR LUMINAIRES

Issuer: Evolt (NZ) Pty Ltd
Address: 485C Rosebank Road
Avondale, Auckland, 1026, NZ

PRODUCT INFORMATION

BRAND	MODEL	SKU
Ektor	EV-RAZOR-CORE-24M	12121

COMPLIANCE

2293 Report	WTF21F03025178N
Safety Report	WTS20D11089962L
EMC Report	WTS20S11088187E
Standards	AS/NZS 60598.1 AS 60598.2.22 AS/NZS 61347.1 AS/NZS 61347.2.13 AS CISPR 15 AS/NZS 2293.3

OPERATIONAL INFORMATION

IP Rating	IP20
Working Temp Range	0 to 40 °C
Input voltage	230Vac
Input Frequency	50 Hz
Driver Type	Fixed output
Product Type	EM EXIT SPU

EMERGENCY INFORMATION

Viewing Distance	24 m
Emergency Mode	Maintained
Emergency Light Source Life	78Y/03M
AS2293.3-2018 Projection of Light source life for LED Exit signs (appendix E) Defines the projected time until the surface luminance falls below the minimum required surface luminance for an exit sign.	
Emergency Duration	90 mins
Decal Size	300 x 150 mm
Emergency Classification	C0:E6.3, C90:E20
Replacement Battery Code	13972

DECLARATION OF COMPLIANCE

On the basis of the test reports specified, I declare that the luminaire described in this document complies with the requirements of electrical safety and the use of the RCM mark.

Title: Managing Director **Date:** 01/01/2021

Signature:

J Newell